



Certificate number: 2003727 (2)

Issued 24/03/2026
Expires 06/08/2026

Kiwa Regulation 4(KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 (issue 7) – Regulation 4(1)(a)
Model number(s) – see Appendix

Etils Ltd

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)(a) of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Replication of this certificate is allowed in its entirety.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en-gb/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Certificate Issued to:

Etils Ltd
Unit 1 Whiting Way
Melbourn
Royston
SG8 6NA



KUKreg4

The following products belong to this certificate

<p>PRODUCT DESCRIPTION Range of rotational moulded cold water storage cisterns with a twist lock lid and brass outlet fitting. ATS3 – Without Production Surveillance.</p>
<p>MODEL(S) ECO75V2, ECO150, ECO260, ECO350V1, ECO350V2, ECO350V3, ECO500V1, ECO500V3, ECOWB500V1, ECOWB500V2, ECO650V1, ECO650V3, ECO750V1, ECO750V3, ECO900, ECO1050V1, ECO1050V2, ECO1050V3, ECO1100U, ECO1300, ECO1450, ECO1600, ECO1900SL, ECO2000TALL, ECO2000, ECO2300, ECO2500, ECO3000, ECO3100, ECO3300, ECO3400, ECO3900, ECO4300, ECO4500, ECO5300, ECO5600, ECO6250, ECO7200, ECO10000, ECO10000TALL, ECO13000, ECO15000, ECO15600, ECO19000, ECO20000, ECO25000</p>
<p>SIZE: Capacity – 75 – 25000 litres</p>
<p>SCOPE: Manufacturer recommended maximum operating temperature: cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.</p>
<p>MARKING Ecosure logo, tel No, website, capacity and potable water tank on adhesive label on body</p>
<p>MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p>BACKFLOW PROTECTION NOTES Every storage cistern, except one supplying water to the primary circuit of a heating system, shall be fitted with a servicing valve on the outlet pipe (s). A servicing valve shall be installed on the supply to the fitting in a readily accessible location. Float-controlled valves or equivalent inlet devices should be securely and rigidly attached to the cistern and installed so that the valve closes when the level of the water is not less than 25 mm below the overflowing level of the cistern. Where the cistern is fitted with an approved alternative to a warning pipe, such as an indicator instrument or visual or audible alarm, the inlet valve is to close when the water level is not less that 50 mm below the overflowing level of the cistern.</p>
<p>ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.</p>

Extra Notes